

# StopWaste


PACKAGED ROOFTOP HEAT PUMP UNITS																																						
TAG	MANUFACTURER & MODEL NO	SERVING	NOM TONS	REFR TYPE	SUPPLY FAN					RETURN/RELIEF FAN					COOLING					HEATING				FILTER			MIN OA (CFM)		ELECTRICAL					OP WT (LBS)	ACCESSORIES	REMARKS		
				WEIGHT (LBS)	CFM	ESP	BHP	HP	ECMVFD	CFM	ESP	BHP	HP	ECMVFD	OADB QAWB	EDB EWB	LDB LWB	CAP (KBH) TOTAL SENS		EER	IEER	CFM	CAP (KBH) HTPMP ELEC		COP47	COP17	TYPE	DEPTH	MERV	DES	ABS	MCA	MOCP				FLA	V/Ø
<div>AC 1</div>	DAIKIN DPS016A	SECOND FLOOR	15	R-410A 53	6100	0.8	3.2	5	VFD	-	-	-	-	-	89	75	51.1	117.6	159.1	11.7	20	6100	146.5	102.4	3.5	2.3	PLEAT	4"	14	1010	970	192.4	200	159.8	208/3	3800	CABINET WITH ECONOMIZER, BOTTOM RETURN AND SUPPLY, VARIABLE SPEED SCROLL COMPRESSOR, SOR ELECTRIC HEAT 30 KW, INTEGRATED BAGNET MSTP, NON-FUSED DISCONNECT, OA FLOW MONITORING STATION, CURB ADAPTER	
<div>AC 2</div>	DAIKIN DPS006A	GROUND FLOOR NORTH	7	R-410A 16.8	2590	0.8	1.01	4	ECM	-	-	-	-	-	67	79.8	53.5	78.4	74.4	11.4	19.3	2590	62.7	-	3.7	2.5	PLEAT	4"	14	365	365	31.8	45	28.1	208/3	1335	CABINET WITH ECONOMIZER, BOTTOM RETURN AND SUPPLY, VARIABLE SPEED SCROLL COMPRESSOR, INTEGRATED BAGNET MSTP, NON-FUSED DISCONNECT, OA FLOW MONITORING STATION, CURB ADAPTER	
<div>AC 3</div>	DAIKIN DPS004A	GROUND FLOOR SOUTH	4	R-410A 12.6	1595	0.7	0.47	4	ECM	-	-	-	-	-	67	74.7	50.3	46.5	42.5	12.1	<sup>16.6</sup> (SEER)	1595	40.4	-	4	-	PLEAT	4"	14	440	440	44	45	37.3	208/3	1335	CABINET WITH ECONOMIZER, BOTTOM RETURN AND SUPPLY, VARIABLE SPEED SCROLL COMPRESSOR, SOR ELECTRIC HEAT 6 KW, INTEGRATED BAGNET MSTP, NON-FUSED DISCONNECT, OA FLOW MONITORING STATION, CURB ADAPTER	
<div>AC 4</div>	DAIKIN DFC0361000001S	SERVER ROOM	3	R-410A -	1128	0.5	-	3/4	-	-	-	-	-	-	67	78.3	55.5	35.4	28.1	11.5	<sup>14</sup> (SEER)	-	-	-	-	-	PLEAT	2"	13	0	0	27.5	40	6.7	208/1	500	CABINET WITH ECONOMIZER, BOTTOM RETURN AND SUPPLY, INTEGRATED BAGNET MSTP, NON-FUSED DISCONNECT, CURB ADAPTER	

PLUMBING WATER HEATER SCHEDULE (ALTERNATE)													
TYPE	EQUIPMENT NUMBER	DESCRIPTION	SERVICE	LOCATION	MANUFACTURER	MODEL	TYPE	FIRST HOUR RATING (GAL)	ELECTRICAL				REMARKS
									WATT	VOLT	PHASE	AMPS	
WH	1	HEAT PUMP WATER HEATER	BUILDING	RM 109	AO SMITH	HPTU-50N	HYBRID HEAT PUMP	66	-	208	1	30	

**taylor** | engineers

1080 Marina Village Parkway  
Suite 501  
Alameda, CA 94501-1142

STAMP

[illegible]

# StopWaste

Drawn by	MU
Scale	12" = 1'-0"

# MECHANICAL SCHEDULES

# M1.01